



Load Settlement System

Procedures and Methods

Effective January 2009



TABLE OF CONTENTS

1. INTRODUCTION	1
2. SITE TO SETTLEMENT ZONE MAPPING	2
3. LOAD PROFILING	2
LOAD RESEARCH SAMPLES	3
SAMPLING ACCURACY REQUIREMENTS	3
HISTORIC CLASS LOAD PROFILES	3
LOAD PROFILING METHOD	4
MODELING ACCURACY REQUIREMENT	5
DEEMED LOAD PROFILES	5
PROFILING CAP	6
4. DISTRIBUTION LOSSES AND UFE	7
HISTORIC LOSS STUDIES	7
SERVICE LEVEL.....	7
CALCULATION OF TOTAL SYSTEM LOSSES.....	8
ALLOCATION OF TOTAL SYSTEM LOSSES.....	9
UNACCOUNTED FOR ENERGY	12
5. OTHER DISCRETIONARY MATTERS	13
ESTIMATION OF CONSUMPTION AMOUNTS.....	13
DEEMED TIMES	13
IMPLEMENTATION ASSUMPTIONS.....	14
APPENDIX A – CALCULATION OF HOURLY SALES, LOSS AND UFE	15
CUMULATIVE METERED AND UNMETERED SITES	15
INTERVAL METERED SITES	16
APPENDIX B – DEVELOPMENT OF THE SYSTEM LOSS EQUATION	17



1. INTRODUCTION

1 ATCO Electric's Load Settlement System is designed to meet the
2 requirements of AUC Rule 021 Settlement System Code Rules (SSC). The
3 SSC is a set of rules established by the AUC under the authority of section
4 24.1(1) of the Electric Utilities Act. All Market Participants as defined in the
5 Electric Utilities Act are required to comply with the SSC.

6 ATCO Electric has been allowed discretion in implementing some aspects of
7 the SSC. Under section 2.8 of the SSC, ATCO Electric, as Load Settlement
8 Agent (LSA), is responsible for making public the procedures and methods
9 used to conduct settlement. The discretionary procedures and methods
10 implemented by ATCO Electric that impact load settlement calculations are
11 described in this document.

12 Two appendices are also included as part of this document. In Appendix A, a
13 method is provided for determining hourly customer site energy consumption
14 (sales), loss and unaccounted for energy (UFE) from the SSC transaction set.
15 Appendix B provides background information with respect to the calculation of
16 the system loss equation parameters.



2. SITE TO SETTLEMENT ZONE MAPPING

1 Section 4.5 2) of the SSC requires ATCO Electric as LSA to disclose
2 individual site to settlement zone mapping rules. ATCO Electric assigns
3 every site for which it is the LSA and all its service territory to a single
4 settlement zone.

3. LOAD PROFILING

5 Section 3.1 1) of the SSC defines the acceptable methods for calculating load
6 profiles.

7 The ATCO Electric load settlement system uses only load research-based
8 profiles or deemed profiles. All customer sites which are not interval metered
9 are assigned a specific class load profile based on their distribution tariff rate
10 class.

11 Each site is assigned a profile class code. Specific codes have been
12 assigned to interval metered sites to indicate such. All other codes are
13 assigned according to rate class. The table below lists the rate classes with
14 their associated profile class codes.

15

Non-Interval Metered Profile Classes	
Rate Class	Profile Class Code
Residential	RES
Farm	FRM
Small General Service	COM
Irrigation	IRR
Street and Private Lighting	LITE
Oilfield	OIL
Large General Service / Industrial	IND

16

Interval Metered Profile Classes	
Customer Site Size	Profile Class Code
Sites < 2 MW	INTV
Sites > 2 MW	INPD

1 Section 3.2 1) of the SSC requires ATCO Electric, as LSA, to state publicly
2 the existing rate classes for which separate load research-based profiles are
3 used in load settlement. The profiles for the residential, farm, small general
4 service and large general service/industrial rate classes are load research-
5 based profiles. Deemed profiles are used for the oilfield, lighting and
6 irrigation classes.

7 The use of class specific load profiles for calculating monthly pool payments
8 ensures that the energy costs are allocated to each class as fairly as
9 possible. However, the cost of such an implementation needs to be balanced
10 against the degree for fairness achieved. The cost/benefit was maximized by
11 combining other load research needs with that of load settlement so as to
12 provide the same degree of fairness to the customer as they previously had.

Load Research Samples

13 Section 8 of the SSC defines the standards for load profiles based on load
14 research samples. For details on the requirements for estimation accuracy,
15 frame adequacy, and sample design and implementation please refer to
16 Section 8 of the SSC.

17 The class load profiles used by ATCO Electric for load settlement are based
18 on historic load surveys. ATCO Electric uses the method of stratified random
19 sampling for the selection of samples to represent each class. This method is
20 commonly used to ensure the most accurate results for a given sample size.
21 A load profile for each class is developed from metered data collected from
22 the selected sites using the combined ratio estimation technique. The value
23 of the load profile for each hour is the energy (kW.h) used in that hour by the
24 average customer site in the class.

Sampling Accuracy Requirements

25 Section 8.2.3 2) of the SSC requires the design sampling variance V_{cs} to meet
26 the following criterion:

27
$$RSE_{cs} = \sqrt{V_{cm}/U_c} < 0.008$$

Historic Class Load Profiles

28 The historical profiles used in load settlement are posted on ATCO Electric's
29 web site and can be accessed at
30 http://www.atcoelectric.com/B_retailers/resource_library.asp.



Load Profiling Method

1 For load research-based profiles, ATCO Electric uses a profiling method
2 known as “proxy day” for estimating class load profiles. The proxy day
3 method compares the available characteristics of the settlement day to the
4 characteristics of historic days. The historic day that best matches the
5 settlement day is used as the proxy day. The historical class profile for that
6 day is then used as the class profile for the settlement day. This process is
7 repeated every day to produce a class load profile for the settlement period.

8 The proxy day method requires a library of class load profiles for historic days
9 as well as associated characteristics for selecting the proxy day. These
10 profiles are developed from the historic load studies described above. The
11 system load profile is a commonly used associated characteristic. The
12 system load profile (DSL) is defined as the settlement zone supply less the
13 load for all transmission connected sites. Other characteristics that may be
14 used include day type, season, temperature and time of the system peak.

15 The proxy day selection process used by ATCO Electric is provided by
16 LODESTAR Corporation. LODESTAR uses a two step process to find a
17 proxy day. The first step uses information about settlement day to select a list
18 of matching “eligible days”. The information used to select the eligible days
19 may include a combination of the following characteristics:

- 20 • Day type
- 21 • Holiday
- 22 • Season
- 23 • System Peak Time
- 24 • Ambient Temperature

25 These parameters may be varied for each profile class to ensure the eligible
26 days selected best represent the characteristics of the class.

27 Once a list of matching eligible days has been selected, the list is ranked by
28 comparing the system load profile for the settlement day to that of each
29 eligible day. Ranking may be done using a “magnitude” comparison or a
30 “shape” comparison. The two methods may also be combined by selecting a
31 weighting factor for each comparison and summing the weighted values. The
32 eligible day with the highest rank is then selected as the proxy day.

33 Once the proxy day selected, the date of the proxy day is used to select the
34 load profile for the class from the library of historic class load profiles.



Modeling Accuracy Requirement

1 Section 8.2.3 2) of the SSC requires the modeling variance V_{cm} to satisfy the
 2 following criterion

3
$$RSE_{cm} = \sqrt{V_{cm}/U_c} < 0.008$$

4 For details regarding this criterion see the section 8 of the SSC.

5 To select the parameters that meet the above criterion for each profile class,
 6 ATCO Electric has analyzed load profile data for the historical period
 7 indicated in the table below. Using the methods described in section 8 of the
 8 SSC, ATCO Electric has determined that the SSC requirements can be met
 9 using the following parameters.

10

	Residential	Farm	Small General Service	Oilfield	Industrial
Historical Period	2004-2006	2004-2006	2004-2006	2004-2006	2004-2006
System Load Profile	scaled DSLS	scaled DSLS	scaled DSLS	DSLS	scaled DSLS
Day Type	Day of Week	Day of Week	None	Week Day/ Weekend	None
Holiday	Yes	No	Yes	Yes	Yes
Season	2 Seasons	4 Seasons	Monthly	2 Seasons	Monthly
Peak Separation	All Peaks	All Peaks	All peaks	All Peaks	All Peaks
Magnitude Weight	0.1	0.1	0.1	0.1	0.1
Shape Weight	0.9	0.9	0.9	0.9	0.9
Achieved RSE_{cm}	.0071	.0056	.0046	.0061	.0009

Deemed Load Profiles

11 Section 3.1 3) of the SSC requires irrigation, oilfield and unmetered loads to
 12 be profiled using a “deemed” shape. ATCO Electric deems the oilfield load
 13 shape to be the one determined from load research samples. The irrigation
 14 load profile is deemed to be flat in the months of April through October. The
 15 value of the profile for each hour is the average hourly energy (kW.h) used by
 16 an irrigation customer site in the period April through October. The value of
 17 the lighting load profile for each hour is a number between 0 and 1 that
 18 represents the proportion of the hour that the lights are on. The deemed load
 19 shape for all other unmetered loads is the load shape of the profile class to
 20 which the customer site belongs.

21 The deemed load profiles used in load settlement are posted on ATCO
 22 Electric’s web site.



Profiling Cap

- 1 Section 3.3 1) of the SSC requires a profiling cap of 2 MW or the WSP's
- 2 current policy, whichever is lower. ATCO Electric's profiling cap is 500 kW
- 3 consistent with currently approved rate schedules. Interval metered customer
- 4 sites that are below the profiling cap and are not a part of a profile class load
- 5 research sample will be settled according to their own interval data.



4. DISTRIBUTION LOSSES AND UFE

1 Section 4.1 2) of the SSC requires ATCO Electric, as a Wires Service
2 Provider (WSP), to provide 90 days notice prior to implementing changes to
3 load settlement loss calculations. This document describes the procedures
4 ATCO Electric will use to perform load settlement loss calculations on and
5 after the effective date of this document. Background information as to how
6 the parameters used in these procedures were derived is also provided.

Historic Loss Studies

7 Section 4.1 1) of the SSC requires the WSPs that have been doing loss
8 calculations as part of cost-of-service studies to continue to use similar
9 methods to those they have been using.

10 The parameters used in the loss calculation procedures described below
11 come from two sources: previous load settlement calculations and distribution
12 loss studies of randomly selected distribution feeders.

13 Annual distribution losses were determined from total annual settlement zone
14 supply less total annual site sales. The source of this information is 2003
15 through 2007 load settlement results adjusted for PFAMs applicable to the
16 same period. The average annual distribution system losses (5.11% of sales)
17 calculated from these results form the basis for determining the required loss
18 calculation parameters.

19 The separation of total distribution losses into primary and secondary
20 distribution losses for each loss group is based on the results of studies
21 ATCO Electric conducted on randomly selected distribution feeder systems.
22 Information on feeder loading, configuration, physical characteristics and the
23 customer mix served from the feeders are used to determine the distribution
24 system losses for each loss group.

Service Level

25 For the purpose of performing loss calculations the ATCO Electric distribution
26 system has been separated into primary and secondary distribution systems.
27 Primary distribution consists of all 3-phase 25 kV lines. There are no
28 transformers in the primary distribution system. Secondary distribution
29 includes all elements of the distribution system that are not part of the primary
30 distribution system.

1 A service level attribute is assigned to each site based on whether the site
 2 takes service directly from the transmission system, from the primary
 3 distribution system or from the secondary distribution system. Sites
 4 connected to the secondary distribution system have a *secondary* service
 5 level. Sites connected to the primary distribution system have a *primary*
 6 service level. Sites that are connected to the transmission system have a
 7 *transmission* service level.

Calculation of Total System Losses

8 Section 2.7 1) of the SSC assigns to ATCO Electric as LSA the responsibility
 9 for calculating distribution losses for each settlement interval.

10 Section 6.4.2 2) of the SSC requires the zone losses to be the sum of the
 11 separately determined retailer losses or to be calculated first and then
 12 allocated to the retailers.

13 For each settlement interval ATCO Electric calculates the total distribution
 14 losses for each service level and allocates these losses to retailers. The
 15 losses are calculated by applying a loss equation to the hourly load for the
 16 distribution system.

17 The primary distribution energy loss for each hour is calculated as follows:

$$18 \quad PL_i = A_{P0} + A_{P2} S_i^2$$

19 Where PL_i is the loss (kW.h) within the primary distribution system in hour i
 20 S_i is the total supply (kW.h) to the distribution system in hour i (does not include
 21 transmission-connected sites)
 22 A_{P0} and A_{P2} are loss equation parameters of the primary distribution system

23 As there are no transformers in the primary distribution system, the constant
 24 loss coefficient A_{P0} is zero. The value of the A_{P2} coefficient for the 2009
 25 settlement year is determined as follows (see Appendix B):

$$26 \quad A_{P2} = \frac{p_p I}{kE} = \frac{(0.0199432)(8760)}{(1.007583866)(9483444640)} = 0.00000001828315$$

27 where p_p is the ratio of the total annual primary energy loss to the total annual energy
 28 supplied to the distribution system from historical studies
 29 I is the number of hours in the year
 30 k is the constant determined from the distribution system load shapes for 2003 to
 31 2007
 32 E is the forecast energy supplied to the AE distribution system for 2009 (kW.h)

1 Thus for each hour the total energy loss for ATCO Electric's primary
 2 distribution system is calculated by multiplying the A_{P2} coefficient by the
 3 square of the hourly energy supplied to the distribution system.

4 The secondary distribution energy loss for each hour is calculated as follows:

$$5 \quad SL_i = A_{S0} + A_{S2}S_i^2$$

6 Where SL_i is the loss (kW.h) within the secondary distribution system in hour i
 7 S_i is the total supply (kW.h) to the distribution system in hour i (does not
 8 include transmission-connected sites)
 9 A_{S0} and A_{S2} are loss equation parameters of the secondary distribution system

10 The values of the A_{S0} and A_{S2} coefficients for the 2009 settlement year are
 11 determined as follows (see Appendix B):

$$12 \quad A_{S0} = \frac{c_s p_s E}{I} = \frac{(0.40)(0.0286726)(9483444640)}{8760} = 12416.19444390$$

$$13 \quad A_{S2} = \frac{p_s I(1 - c_s)}{kE} = \frac{(0.0286726)(8760)(1 - 0.40)}{(1.007583866)(9483444640)} = 0.00000001577156$$

14 where p_s is the ratio of the total annual secondary energy loss to the total annual energy
 15 supplied to the distribution system from historical studies
 16 I is the number of hours in the year
 17 c_s is the ratio of the annual constant loss to the total annual loss in the secondary
 18 distribution system
 19 k is the constant determined from the distribution system load shape for 2003 to
 20 2007
 21 E is the forecast energy supplied to the AE distribution system for 2009 (kW.h)

22 For each hour the total energy loss for ATCO Electric's secondary distribution
 23 system is calculated by multiplying A_{S2} by the square of the hourly energy
 24 supplied to the distribution system and adding A_{S0} .

Allocation of Total System Losses

25 Section 2.7 1) of the SSC assigns to ATCO Electric as LSA the responsibility
 26 for establishing the formulas for allocating distribution losses for each interval
 27 to the customer sites.

28 ATCO Electric allocates distribution system losses by loss group which is
 29 comprised of service level and loss class. The secondary distribution loss
 30 allocated to each site by hour is calculated using the following equations:

$$SL_{si} = SF_i \cdot SA_s \cdot E_{si} \qquad SF_i = \frac{SL_i}{\sum_{\text{all } s} SA_s \cdot E_{si}}$$

Where SL_{si} is the secondary loss (kW.h) allocated to site s in hour i
 SF_i is the factor that ensures all secondary loss for hour i is allocated
 SA_s is the secondary loss allocation factor (see table below) for the loss group
to which site s belongs
 E_{si} is the energy sales (kW.h) for site s in hour i
 SL_i is the total secondary loss (kW.h) in hour i

The primary distribution loss allocated to each site by hour is calculated using the following equations:

$$PL_{si} = PF_i \cdot PA_s \cdot (E_{si} + SL_{si}) \qquad PF_i = \frac{PL_i}{\sum_{\text{all } s} PA_s \cdot (E_{si} + SL_{si})}$$

Where PL_{si} is the primary loss (kW.h) allocated to site s in hour i
 PF_i is the factor that ensures all primary loss for hour i is allocated
 PA_s is the primary loss allocation factor (see table below) for the loss group
to which site s belongs
 E_{si} is the energy sales (kW.h) allocated to site s in hour i
 PL_i is the total primary loss (kW.h) in hour i

The loss allocation factors used were developed from an analysis of historic load profile data and distribution loss studies. For the years 2005 through 2007 the distribution system losses were modeled using the distribution system supply load profile as well as load profiles, annual energy sales, and annual energy losses for each loss group. The loss group load profiles were developed from the hourly loads of sample sites. The annual energy sales were calculated from site metering. The annual energy losses are calculated from historic loss studies.

The following procedure was used to develop the loss allocation factors for the primary and secondary distribution systems separately. Total loss profiles for each year were estimated using a load/loss relationship of the form described above. Next, initial loss allocation factors for each loss group were calculated by dividing the annual energy losses by the annual energy sales for each loss group. An iterative process was then used to refine the loss allocation factors. The first step consisted of scaling the load profile for each loss group to the group annual energy loss using the estimated loss allocation factors. In the second step the resulting group loss profile was adjusted for each hour so that the sum of losses for all the loss groups was equal to the total loss profile. Because this hourly adjustment changed the shape of the group loss profiles the loss allocation factors were readjusted. This iterative



1 process was repeated and the loss allocation factors refined until the
 2 difference between the total loss profile energy and the annual energy loss for
 3 each loss group was less than 0.3%.

4 The loss allocation factors for each loss group determined for each year were
 5 averaged to arrive at the loss allocation factors reported below.

6

Loss Group		Loss Group Code	Secondary Loss Allocation Factor (SA _s)	Primary Loss Allocation Factor (PA _s)
Loss Class	Service Level			
Residential	Secondary	RESSECN	0.0336	0.0165
Residential	Primary	RESPRIM	0	0.0165
Residential	Transmission	RESTRAN	0	0
REA and Co Farm	Secondary	FRMSECN	0.0330	0.0246
REA and Co Farm	Primary	FRMPRIM	0	0.0246
REA and Co Farm	Transmission	FRMTRAN	0	0
Small General Service	Secondary	COMSECN	0.0380	0.0145
Small General Service	Primary	COMPRIM	0	0.0145
Small General Service	Transmission	COMTRAN	0	0
Irrigation	Secondary	IRRSECN	0.0382	0.0340
Irrigation	Primary	IRRPRIM	0	0.0340
Irrigation	Transmission	IRRTRAN	0	0
Street Lighting	Secondary	STLSSECN	0.0271	0.0169
Street Lighting	Primary	STLSPRIM	0	0.0169
Street Lighting	Transmission	STLSTRAN	0	0
Private Lighting	Secondary	SENTSECN	0.0324	0.0187
Private Lighting	Primary	SENTPRIM	0	0.0187
Private Lighting	Transmission	SENTTRAN	0	0
Oilfield	Secondary	OILSECN	0.0365	0.0297
Oilfield	Primary	OILPRIM	0	0.0297
Oilfield	Transmission	OILTRAN	0	0
Industrial < 2 MW	Secondary	INDSECN	0.0336	0.0255
Industrial < 2 MW	Primary	INDPRIM	0	0.0215
Industrial < 2 MW	Transmission	INDTRAN	0	0
Industrial > 2 MW	Secondary	INPDSECN	0.0267	0.0131
Industrial > 2 MW	Primary	INPDPRIM	0	0.0089
Industrial > 2 MW	Transmission	INPDTRAN	0	0

7 The target annual energy loss expressed as a percentage of sales for the loss
 8 group to which customer site s belongs can be calculated as follows:

9
$$P_s = 100 \cdot [PA_s + SA_s + (PA_s \cdot SA_s)]$$

10 Where P_s is the percentage annual energy loss for the loss group to which site s belongs
 11 PA_s is the primary loss allocation factor for the loss group to which site s
 12 SA_s is the secondary loss allocation factor for the loss group to which site s
 13 belongs



Unaccounted For Energy

1 Section 4.2.1 of the SSC requires that the UFE calculated for each hour be
2 allocated to the customer sites of all retailers in proportion to their settled load
3 and allocated losses. Transmission-connected customer sites billed using the
4 same interval metered data as is used in the calculation of POD load are
5 exempt from this calculation.

6 ATCO Electric allocates UFE for each hour in proportion to the sales and
7 associated losses for that hour. The following formula is used for this
8 purpose:

$$9 \quad U_{si} = UF_i \cdot W_{si} \cdot (E_{si} + PL_{si} + SL_{si}) \quad UF_i = \frac{U_i}{\sum_{\text{all } s} W_{si} \cdot (E_{si} + PL_{si} + SL_{si})}$$

10 Where U_{si} is the UFE (kW.h) allocated to site s in hour i
11 UF_i is the factor that ensures all UFE for hour i is allocated
12 E_{si} is the energy sales (kW.h) for site s in hour i
13 PL_{si} is the primary loss (kW.h) allocated to site s in hour i
14 SL_{si} is the secondary loss (kW.h) allocated to site s in hour i
15 U_i is the total UFE (kW.h) in hour i
16 W_{si} is 0 for UFE exempt sites in hour i and 1 for all other sites in hour i



5. OTHER DISCRETIONARY MATTERS

Estimation of Consumption Amounts

1 Section 2.6 3) of the SSC assigns to ATCO Electric, as LSA, the responsibility
2 of estimating cumulative consumption amounts (sales) where consumption
3 calculated from meter readings is not yet available. For initial daily, initial
4 monthly, interim reconciliation and final reconciliation settlement these
5 estimates are based on customer rate class profiles and energy sales from
6 the most recent period for which energy sales between actual reads is
7 available as follows:

$$8 \quad E_{si} = \frac{E_{DCM} \cdot P_{ci}}{\sum_{i \in m} P_{ci}}$$

9 Where E_{si} is the energy sales (kW.h) estimated for site s in hour i
10 P_{ci} is the average site energy (kW.h) for profile class c in hour i
11 E_{DCM} is the energy sales (kW.h) for site s from the most recent DCM covering
12 reading period m that ends prior to the profile freeze date.

13 When cumulative metered sites switch Retailer/RRP's, section 7.4 7) of the
14 SSC requires the LSA to estimate the site energy consumption from the last
15 meter read to the time of the switch. This estimate is calculated as follows:

$$16 \quad E_{CSE} = \frac{E_{DCM} \cdot D_{CSE}}{D_{DSM}}$$

17 Where E_{CSE} is the energy sales (kW.h) estimated for the site between the switch and the
18 prior meter reading
19 D_{CSE} is the number of days between the switch and the prior meter reading
20 E_{DCM} is the energy sales (kW.h) for customer site from the most recent DCM whose
21 reading period is D_{DCM} days.

Deemed Times

22 Section 2.14 of the SSC allows ATCO Electric, as WSP, to define an
23 assumed time of day for the reading of cumulative meters as well as for
24 energize and de-energize events. For the purpose of performing load
25 settlement, ATCO Electric deems these events to have taken place at the end
26 of the day during which they were actually performed.



Implementation Assumptions

- 1 Section 6.2 1) of the SSC specifies assumptions under which the calculation
- 2 formulas of section 6.4 have been developed. These assumptions are that
- 3 energization, de-energization and profile class changes for a customer site
- 4 will always be accompanied with a meter read on the same day and that
- 5 switch of retailer will not necessarily be accompanied by a meter read. ATCO
- 6 Electric has implemented the settlement calculations consistent with these
- 7 assumptions.

APPENDIX A – CALCULATION OF HOURLY SALES, LOSS AND UFE

1 In this appendix, a method is provided for determining hourly customer site
2 sales, loss and UFE from the SSC transaction set.

3
4 In the following:

- 5 • The WCI, WSD and SPI transactions used must be from the same
6 settlement run.
- 7 • Cumulative meter reads, energization, de-energization, profile class
8 changes and retailer switches are all deemed to occur on daily
9 boundaries.
- 10 • Site *s* is a member of profile class *c* as well as loss group *g* and is enrolled
11 to retailer *r* on day *d* which is in meter reading period *m*.
- 12 • Hour *i* is within day *d*.

Cumulative Metered and Unmetered Sites

13 Hourly sales, loss and UFE for cumulative metered and unmetered sites can
14 be calculated as follows:

$$15 \quad E_{si} = \frac{E_{sd} E_{rcgi}}{\sum_{i \in d} E_{rcgi}}$$

$$16 \quad L_{si} = \frac{L_{sd} L_{rcgi}}{\sum_{i \in d} L_{rcgi}}$$

$$17 \quad U_{si} = \frac{U_{sd} U_{rcgi}}{\sum_{i \in d} U_{rcgi}}$$

18 Where E_{si} is the energy sales (kW.h) for site *s* in hour *i*
19 E_{sd} is the energy sales (kW.h) for site *s* in day *d* (from the WSD transaction)
20 E_{rcgi} is the energy sales (kW.h) for all sites with retailer *r*, profile class *c* and loss
21 group *g* in hour *i* (from the WCI transaction)
22 L_{si} is the energy loss (kW.h) for site *s* in hour *i*
23 L_{sd} is the energy loss (kW.h) for site *s* in day *d* (from the WSD transaction)
24 L_{rcgi} is the energy loss (kW.h) for all sites with retailer *r*, profile class *c* and loss
25 group *g* in hour *i* (from the WCI transaction)
26 U_{si} is the UFE (kW.h) for site *s* in hour *i*
27 U_{sd} is the UFE (kW.h) for site *s* in day *d* (from the WSD transaction)
28 U_{rcgi} is the UFE (kW.h) for all sites with retailer *r*, profile class *c* and loss group *g*
29 in hour *i* (from the WCI transaction)

Interval Metered Sites

1 Hourly sales, loss and UFE for cumulative metered and unmetered sites can
 2 be calculated as follows:

$$3 \quad L_{si} = \left(\frac{L_{rcgi}}{E_{rcgi}} \right) E_{si} W_{si}$$

4

$$5 \quad U_{si} = \left(\frac{U_{rcgi}}{E_{rcgi}} \right) E_{si} W_{si}$$

6 Where E_{si} is the energy sales (kW.h) for site s in hour i (from the DIM transactions
 7 available at the time of the settlement run)
 8 E_{rcgi} is the energy sales (kW.h) for all sites with retailer r , profile class c and loss
 9 group g in hour i (from the WCI transaction)
 10 L_{si} is the energy loss (kW.h) for site s in hour i
 11 L_{rcgi} is the energy loss (kW.h) for all sites with retailer r , profile class c and loss
 12 group g in hour i (from the WCI transaction)
 13 U_{si} is the UFE (kW.h) for site s in hour i
 14 U_{rcgi} is the UFE (kW.h) for all sites with retailer r , profile class c and loss group g
 15 in hour i (from the WCI transaction)
 16 W_{si} is a weighting factor that has the value 0 if site s is transmission-connected in
 17 hour i in day d (from the WSD transactions) and a value of 1 if it is not

18 Note that the last formula does not work for a transmission-connected site
 19 that is not deemed to be a direct connect site according to section 5.3.8 2) a)
 20 iii) of the SSC.

1 APPENDIX B – DEVELOPMENT OF THE SYSTEM LOSS EQUATION

2 In this appendix the coefficients of the following system loss equation are
3 developed.

$$4 \quad l_i = A_0 + A_2 e_i^2$$

5 Where l_i is the system loss for hour i
6 e_i is the system load for hour i
7 A_0 is the constant coefficient associated with transformer core losses
8 A_2 is the coefficient associated with resistive line losses

9 **Assumptions**

- 10 • Total distribution system transformer capacity grows at approximately
11 the same rate as the load growth in the distribution system.
- 12 • The load growth for the secondary and primary distribution systems is
13 approximately the same.

14 **Definition of Variables**

15 e_i is the energy flow in interval i into the distribution system.
16 c is the ratio of the annual constant energy loss to the annual total
17 energy loss.
18 p is the ratio of the annual total energy loss to the annual total energy
19 flow into the system
20 l_i is the total energy loss in the distribution system in interval i
21 I is the total number of intervals in the year.
22 L is the total energy loss for the year
23 E is the total energy entering the system during the year.

24 By Definition

$$25 \quad E = \sum_{i=1}^I e_i \quad 1$$

$$26 \quad c = \frac{\text{Annual Constant Energy Loss}}{L} \quad 2$$

$$27 \quad p = \frac{L}{E} \quad 3$$

$$28 \quad L = \sum_{i=1}^I l_i \quad 4$$

1 From the system loss equation

$$2 \quad l_i = A_0 + A_2 e_i^2 \quad 5$$

$$3 \quad \text{Annual Constant Energy Loss} = \sum_{i=1}^I A_0 = A_0 I \quad 6$$

4 Combining 4, 5 and 6

$$5 \quad L = \sum_{i=1}^I l_i = \sum_{i=1}^I A_0 + \sum_{i=1}^I A_2 e_i^2 = A_0 I + A_2 \sum_{i=1}^I e_i^2 \quad 7$$

6 From equation 2 and 3

7

$$8 \quad \text{Annual Constant Energy Loss} = cpE \quad 8$$

9 Combining 6 and 8

$$10 \quad A_0 = \frac{cpE}{I} \quad 9$$

11 Combining equation 3, 7 and 9

$$12 \quad pE = cpE + A_2 \sum_{i=1}^I e_i^2$$

13 Solving for A2

$$14 \quad A_2 = \frac{pE(1-c)}{\sum_{i=1}^I e_i^2} \quad 10$$

15 Substituting 9 and 10 into 5 the equation for the total loss for interval i
16 becomes

$$17 \quad l_i = \frac{cpE}{I} + \frac{pE(1-c)}{\sum_{i=1}^I e_i^2} e_i^2 \quad 11$$

1 The value of c and p can be determined from historic loss studies and E is
2 normally forecasted. The value that is not readily available is the sum of the
3 square of the interval energy. This value can be determined from its
4 relationship to E , the annual energy supplied to the system.

5 From historic load data, it has been found that over a calendar year, the
6 average of the square of the interval energy has a linear relationship to the
7 square of the average interval energy.

$$\frac{\sum_{i=1}^I e_i^2}{I} = k \left(\frac{E}{I} \right)^2$$

8
9 Simplifying the equation we have

$$\sum_{i=1}^I e_i^2 = k \frac{E^2}{I} \quad 12$$

11 Solving for the constant k

$$k = \frac{I \sum_{i=1}^I e_i^2}{E^2} \quad 13$$

13 By calculating an average k for historic interval energy, the sum of the square
14 of the interval energy may be estimated from the forecast annual energy. The
15 resulting energy loss equation for interval i becomes:

$$l_i = \frac{cpE}{I} + \frac{pI(1-c)}{kE} e_i^2 \quad 14$$

17 And the loss coefficients are:

$$A_0 = \frac{cpE}{I} \quad A_2 = \frac{pI(1-c)}{kE} \quad 15$$

1 If we define the following relationships, the loss equation can be
2 disaggregated to the primary and secondary distribution systems.

$$3 \quad p = p_s + p_p \qquad cp = c_s p_s + c_p p_p$$

4 Where c_p is the ratio of the annual constant energy loss in the secondary distribution
5 system to the total annual energy loss in the secondary distribution system
6 c_s is the ratio of the annual constant energy loss in the primary distribution system
7 to the total annual energy loss in the primary distribution system
8 p_p is the ratio of the total annual energy loss in the primary distribution system to
9 the annual energy supply to the distribution system
10 p_s is the ratio of the total annual energy loss in the secondary distribution system to
11 the annual energy supply to the distribution system

12 As there are no transformers in the primary distribution system, c_p is equal to
13 zero and the loss coefficients for the primary distribution system becomes

$$14 \quad A_{p0} = 0 \qquad A_{p2} = \frac{p_p I}{kE}$$

15 And the loss coefficients for the secondary distribution system are

$$16 \quad A_{s0} = \frac{c_s p_s E}{I} \qquad A_{s2} = \frac{p_p I (1 - c_s)}{kE}$$